

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE

NRCC-MCH-E

This document is used to demonstrate compliance for mechanical systems that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in [§140.4](#), or [§141.0\(b\)2](#) for alterations.

Project Name: Mountain Empire Jr & Senior high school AC 1 replacement **Report Page:** (Page 1 of 9)

Project Address: **Date Prepared:** 2021-08-30T17:28:15-04:00

A. GENERAL INFORMATION

01	Project Location (city)	Spring Valley	04	Total Conditioned Floor Area	9790
02	Climate Zone	14	05	Total Unconditioned Floor Area	0
03	Occupancy Types Within Project:		06	# of Stories (Habitable Above Grade)	1
<input type="checkbox"/>	Office (B)	<input type="checkbox"/>	<input type="checkbox"/>	Retail (M)	<input type="checkbox"/>
<input type="checkbox"/>	Hotel/ Motel Guest Rooms (R-1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	School (E)	<input type="checkbox"/>
<input type="checkbox"/>	High-Rise Residential (R-2/R-3)	<input type="checkbox"/>	<input type="checkbox"/>	Relocatable Class Bldg (E)	<input type="checkbox"/>
<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	Non-refrigerated Warehouse (S)	
			<input type="checkbox"/>	Healthcare Facility (I)	
			<input type="checkbox"/>	Other (write in)	

B. PROJECT SCOPE

This table Includes mechanical systems or components that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in [§140.4](#), or [§141.0\(b\)2](#) for alterations.

01	02	03
Air System(s)	Wet System Components	Dry System Components
<input checked="" type="checkbox"/> Heating Air System	<input type="checkbox"/> Water Economizer	<input checked="" type="checkbox"/> Air Economizer
<input checked="" type="checkbox"/> Cooling Air System	<input type="checkbox"/> Pumps	<input type="checkbox"/> Electric Resistance Heat
Mechanical Controls	<input type="checkbox"/> System Piping	<input type="checkbox"/> Fan Systems
<input type="checkbox"/> Mechanical Controls (existing to remain, altered or new)	<input type="checkbox"/> Cooling Towers	<input checked="" type="checkbox"/> Ductwork (existing to remain, altered or new)
	<input type="checkbox"/> Chillers	<input checked="" type="checkbox"/> Ventilation
	<input type="checkbox"/> Boilers	<input type="checkbox"/> Zonal Systems/ Terminal Boxes

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page: (Page 2 of 9)
Project Address:		Date Prepared: 2021-08-30T17:28:15-04:00

C. COMPLIANCE RESULTS

Table C will indicate if the project data input into the compliance document is compliant with mechanical requirements. This table is not editable by the user. If this table says "DOES NOT COMPLY" or "COMPLIES with Exceptional Conditions" refer to Table D., or the table indicated as not compliant for guidance.

01		02		03		04		05		06		07		08	09	
System Summary §110.1 , §110.2 , §140.4	AND	Pumps §140.4(k)	AND	Fans/ Economizers §140.4(c) , §140.4(e)	AND	System Controls §110.2 , §120.2 , §140.4(f)	AND	Ventilation §120.1	AND	Terminal Box Controls §140.4(d)	AND	Distribution §120.3 , §140.4(l)	AND	Cooling Towers §110.2(e)2	Compliance Results	
(See Table F)		(See Table G)		(See Table H)		(See Table I)		(See Table J)		(See Table K)		(See Table L)		(See Table M)		
Yes	AND		AND	Yes	AND	Yes	AND	Yes	AND		AND	Yes	AND			COMPLIES
Mandatory Measures Compliance (See Table Q for Details)										COMPLIES						

D. EXCEPTIONAL CONDITIONS

This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

E. ADDITIONAL REMARKS

This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E	
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page:	(Page 3 of 9)
Project Address:		Date Prepared:	2021-08-30T17:28:15-04:00

F. HVAC SYSTEM SUMMARY (DRY & WET SYSTEMS)

This table is used to demonstrate compliance for mechanical equipment with mandatory requirements found in [§110.1](#) and [§110.2\(a\)](#) and prescriptive requirements found in [§140.4\(a\)](#), [§140.4\(b\)](#) and [§140.4\(k\)](#) or [§141.0\(b\)2](#) for alterations.

Dry System Equipment Sizing (includes air conditioners, condensers, heat pumps, VRF, furnaces and unit heaters)

01	02	03	04	05	06	07	08	09	10	11		
Name or Item Tag	Equipment Category per Tables 110.2	Equipment Type per Tables 110.2 / Title 20	Smallest Size Available ¹ §140.4(a)	Equipment Sizing per Mechanical Schedule (kBtu/h) §140.4 (a&b)								
				Heating Output ^{2,3}			Cooling Output ^{2,3}		Load Calculations ^{3,4}			
				Per Design (kBtu/h)	Rated (kBtu/h)	Supp. Heating Output (kBtu/h)	Sensible Per Design (kBtu/h)	Rated (kBtu/h)	Total Heating Load (kBtu/h)	Total Sensible Cooling Load (kBtu/h)		
AC 1	Unitary AC/ Condensers	AC, air-cooled pkg (3 phase)	Yes				269.89	314.5		300		

¹FOOTNOTES: Equipment shall be the smallest size, within the available options of the desired equipment line, necessary to meet the design heating and cooling loads of the building per [§140.4\(a\)](#). Healthcare facilities are exempted.

²It is common practice to show rated output capacity on the equipment schedule. Sensible cooling output comes from specification sheet tables.

³If equipment is heating only, leave cooling output and load blank. If equipment is cooling only, leave heating output and load blank.

⁴Authority Having Jurisdiction may ask for load calculations used for compliance per [§140.4\(b\)](#).

Dry System Equipment Efficiency (other than Package Terminal Air Conditioners (PTAC) and Package Terminal Heat Pumps (PTHP))

01	02	03	04	05	06	07	08	09
Name or Item Tag	Size Category (Btu/h)	Heating Mode				Cooling Mode		
		Rating Condition (°F)	Efficiency Unit	Minimum Efficiency Required per Tables 110.2 / Title 20	Design Efficiency	Efficiency Unit	Minimum Efficiency Required per Tables 110.2 / Title 20	Design Efficiency
AC 1	>=240,000 and <760,000					EER IEER	10 11.6	10.8 14.5

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page: (Page 4 of 9)
Project Address:		Date Prepared: 2021-08-30T17:28:15-04:00

G. PUMPS

This section does not apply to this project.

H. FAN SYSTEMS & AIR ECONOMIZERS

This table is used to demonstrate compliance with prescriptive requirements found in [§140.4\(c\)](#), [§140.4\(e\)](#) and [§140.4\(m\)](#) for fan systems. Fan systems serving only process loads are exempt from these requirements and do not need to be included in Table H.

System Name:	AC 1	Economizer: ¹	Fixed Temperature	Economizer Controls:	Designed per §140.4(e) and (m)	System Fan Type:	Variable Air Volume
01	02	03	04	05	06	07	08
Fan Name or Item Tag	Fan Function	Qty	Maximum Design Supply Airflow (CFM)	HP Unit ²	Design HP	Fan Power Pressure Drop Adjustment - Table 140.4-B	
						Device	Design Airflow through Device (CFM)
AC 1 supply fan	Supply	1	10000	BHP	6.79	MERV 13-15 (Alterations only)	10000
						Calculated Adjustment (in H ₂ O)	
Total System Design Supply Airflow (CFM):			10000	Total System Design (B)HP:	6.79	Maximum System Fan Power (B)HP:	15.18

¹ FOOTNOTES: Computer room economizers must meet requirements of [§140.9\(a\)](#) and will be documented on the NRCC-PRC-E document.

² The unit used for HP must be consistent for all fans within a system.

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page: (Page 5 of 9)
Project Address:		Date Prepared: 2021-08-30T17:28:15-04:00

I. SYSTEM CONTROLS

This table is used to demonstrate compliance with mandatory controls in [§110.2](#) and [§120.2](#) and prescriptive controls in [§140.4\(f\)](#) and (n) or requirements in [§141.0\(b\)2E](#) for altered space conditioning systems.

01	02	03	04	05	06	07	08	09
System Name	System Zoning	Conditioned Floor Area Being Served (ft ²)	Thermostats §110.2(b) & (c) ¹ , §120.2(a) or §141.0(b)2E	Shut-Off Controls §120.2(e)	Isolation Zone Controls §120.2(g)	Demand Response §110.12 and §120.2(b)	Supply Air Temp. Reset §140.4(f)	Window Interlocks per §140.4(n)
AC 1	Multi-zone	<= 25,000 ft ²	EMCS	NA: Altered per §141.0(b)2E	NA: Altered per §141.0(b)2E	EMCS	NA: Alteration	NA: Alteration Project

¹FOOTNOTES: Gravity gas wall heaters, gravity floor heaters, gravity room heaters, non-central electric heaters, fireplaces or decorative gas appliances, wood stoves are not required to have setback thermostats.

*Notes: Controls with a * require a note in the space below explaining how compliance is achieved. EX: system 1: SA Temp Reset: Exempt because zones compliant with [§140.4\(d\)](#); EXCEPTION 1 to [§140.4\(f\)](#)

J. VENTILATION AND INDOOR AIR QUALITY

This table is used to demonstrate compliance with mandatory ventilation requirements in [§120.1](#) and [§120.2\(e\)3B](#) for all nonresidential, high-rise residential and hotel/motel occupancies. For alterations, only ventilation systems being altered within the scope of the permit application need to be documented in this table. In lieu of this table, the required outdoor ventilation rates and airflows may be shown on the plans or the calculations can be presented in a spreadsheet.

01	<input type="checkbox"/>	Check the box if the project is showing ventilation calculations on the plans, or attaching the calculations instead of completing this table.
02	<input checked="" type="checkbox"/>	Check this box if the project included Nonresidential or Hotel/Motel spaces
	<input type="checkbox"/>	Check this box if the project included new or altered high-rise residential dwelling units.
03	<input type="checkbox"/>	Check the box if the project is using natural ventilation in any nonresidential or hotel/motel spaces to meet required ventilation rates per §120.1(c)2 .

Nonresidential and Hotel/ Motel Ventilation Systems

04		05		06		07		
System Name	AC 1	System Design OA CFM Airflow ¹	3721	System Design Transfer Air CFM	0	Air Filtration per §120.1(c) and §141.0(b)2 ² Provided per §141.0(b)2c (alteration)		
08	09	10	11	12	13	14	15	16

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page: (Page 6 of 9)
Project Address:		Date Prepared: 2021-08-30T17:28:15-04:00

J. VENTILATION AND INDOOR AIR QUALITY

Space Name or item Tag	Mechanical Ventilation Required per §120.1(c)3 ³					Exh. Vent per §120.1(c)4		DCV or Sensor Controls per §120.1(d)3 , §120.1(d)5 , and §120.1(e)3 ⁶	
	Occupancy Type ⁴	Conditioned Floor Area (ft ²)	# of Shower heads/ toilets	# of people ⁵	Required Min OA CFM	Required Min CFM	Provided per Design CFM		
Building A south	Classroom (ages 5-18)	9790			3720.2			DCV	NA: Not required per §120.1(d)3
								Occ Sensor	NA: Not required space type
17	Total System Required Min OA CFM				3720.2	18	Ventilation for this System Complies?		Yes

¹ FOOTNOTES: System CFM should include both mechanical and natural ventilation for the zone/system

² Air filtration requirements apply to the following three system types per [§120.1\(c\)1A](#) : space conditioning systems utilizing ducts to supply air to occupiable space; supply-only ventilation systems providing outside air to occupiable space; supply side of balanced ventilation systems including heat recovery and energy recovery ventilation systems providing outside air to occupiable space.

³ Uniform Mechanical Code may have more stringent ventilation requirements; the most stringent code requirement takes precedence.

⁴ See Standards Tables 120.1-A and 120.1-B.

⁵ For lecture halls with fixed seating, the expected number of occupants shall be determined in accordance with the California Building Code.

⁶ [§120.2\(e\)3](#) requires systems serving rooms that are required by [§130.1\(c\)](#) to have lighting occupancy sensing controls to also have occupancy sensing zone controls for ventilation. Examples of spaces which require lighting occupancy sensors include offices 250ft² or smaller, multipurpose rooms less than 1,000 ft², classrooms, conference rooms, restrooms, aisles and open areas in warehouses, library book stack aisles, corridors, stairwells, parking garages, and loading and unloading zones, unless excepted by [§130.1\(c\)](#).

K. TERMINAL BOX CONTROLS

This section does not apply to this project.

L. DISTRIBUTION (DUCTWORK and PIPING)

This table is used to show compliance with mandatory pipe insulation requirements found in [§120.3](#) and prescriptive requirements found in [§140.4\(l\)](#) for duct leakage testing.

Duct Leakage Sealing

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page: (Page 7 of 9)
Project Address:		Date Prepared: 2021-08-30T17:28:15-04:00

L. DISTRIBUTION (DUCTWORK and PIPING)

The answers to the questions below apply to the following duct systems:		Roof top ductwork is existing to remain with no new ductwork added	Duct leakage testing triggered for these systems?	No
11	No	The scope of the project includes only duct systems serving healthcare facilities		
12	No	Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.		
13	No	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.		
14	No	The <u>combined</u> surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:		
		<input type="checkbox"/>	Outdoors	
		<input type="checkbox"/>	In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)1B or if the roof has fixed vents or openings to the outside/ unconditioned spaces	
		<input type="checkbox"/>	In an unconditioned crawl space	
		<input type="checkbox"/>	In other unconditioned spaces	
15	No	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.		
16	No	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.		
17		Duct system shall be sealed in accordance with the California Mechanical Code		

M. COOLING TOWERS

This section does not apply to this project.

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCI/

Form/Title	Field Inspector	
	Pass	Fail
NRCI-MCH-01-E - Must be submitted for all buildings	<input type="checkbox"/>	<input type="checkbox"/>

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22

Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E	
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page:	(Page 8 of 9)
Project Address:		Date Prepared:	2021-08-30T17:28:15-04:00

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	
		Pass	Fail
NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap.	AC 1	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-05-A - Air Economizer Controls	AC 1	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-07-A Supply Fan Variable Flow Controls	AC 1 supply fan	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-12-A FDD for Packaged Direct Expansion Units	AC 1	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-18-A Energy Management Control Systems	AC 1	<input type="checkbox"/>	<input type="checkbox"/>

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION

There are no NRCV forms required for this project.

Q. MANDATORY MEASURES DOCUMENTATION LOCATION

This table is used to indicate where mandatory measures are documented in the plan set or construction documentation.

01	02
Compliance with Mandatory Measures documented through MCH Mandatory Measures Note Block	No
	Plan sheet or construction document location Mechanical sheets M001 thru M601

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22


Mechanical Systems

NRCC-MCH-E

CERTIFICATE OF COMPLIANCE		NRCC-MCH-E
Project Name:	Mountain Empire Jr & Senior high school AC 1 replacement	Report Page: (Page 9 of 9)
Project Address:		Date Prepared: 2021-08-30T17:28:15-04:00

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT


I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Jeffrey Ogle	Documentation Author Signature: 
Company: Salasobrien	Signature Date: 08/30/2021
Address: 3220 Executive Ridge, Suite 210	CEA/ HERS Certification Identification (if applicable):
City/State/Zip: Vista, CA 92081	Phone: 760-560-0100

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer)
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Jeffrey Ogle	Responsible Designer Signature: 
Company: Salasobrien	Date Signed: 08/30/2021
Address: 3220 Executive Ridge, Suite 210	License:
City/State/Zip: Vista, CA 92081	Phone: 760-560-0100

Registration Number:

Registration Date/Time:

Registration Provider: Energy Code Ace

CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance

Report Version: 2019.1.003
Schema Version: rev 20200601

Report Generated: 2021-08-30 14:28:22